



## CITY OF ATLANTA

SUITE 1900

55 TRINITY AVENUE, SW

ATLANTA, GA 30303

(404) 330-6204 Fax: (404) 658-7705

Internet Home Page: [www.atlantaga.gov](http://www.atlantaga.gov)

Kasim Reed  
Mayor

DEPARTMENT OF PROCUREMENT  
Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP  
Chief Procurement Officer  
[asmith@atlantaga.gov](mailto:asmith@atlantaga.gov)

August 14, 2014

Dear Potential Bidders:

**Re: FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson Atlanta International Airport**

Attached is one (1) copy of **Addendum No. 3**, which is hereby made a part of the above-referenced project.

For additional information, please contact Mr. Leslie H. Page, Contracting Officer, at (404) 330-6107, or via e-mail at [lpag@atlantaga.gov](mailto:lpag@atlantaga.gov).

Sincerely,

A handwritten signature in cursive script that reads "Adam L. Smith".

Adam L. Smith

ALS:lhv

**Addendum No. 3**

**Re: FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson  
Atlanta International Airport**

August 14, 2014

Page 2

This Addendum forms a part of the Invitation to Bid and modifies the original solicitation package and any prior Addenda as noted below:

**Revision to Technical Specification.**

**Questions and Answers.**

Proposals are due **Wednesday, August 20, 2014**, should be time stamped in no later than 2:00 p.m., and delivered to the address below:

Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP  
Chief Procurement Officer  
Department of Procurement  
55 Trinity Avenue, S.W.  
City Hall South, Suite 1900  
Atlanta, Georgia 30303

**\*\* All other information remains unchanged \*\***

**Addendum No. 3**

**Re: FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson  
Atlanta International Airport**

August 14, 2014

Page 3

**Acknowledgment of Addendum No. 3**

Bidders must sign below and return this form with Bids to the Department of Procurement, 55 Trinity Avenue, City Hall South, Suite 1900, Atlanta, Georgia 30303 as acknowledgment of receipt of this Addendum.

This is to acknowledge receipt of Addendum No. 3 for **FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson Atlanta International Airport** on this the \_\_\_\_\_ day of \_\_\_\_\_, 2014.

\_\_\_\_\_  
Legal Company Name of Proponent

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

**Addendum No. 3**

**Re: FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson  
Atlanta International Airport**

August 14, 2014

Page 4

**MODIFICATIONS ARE INDICATED IN BOLD ITALIC FACE TYPE**

The following questions and/or clarifications were requested by various Contractors:

1. Question: I was wondering who the project managers were for: Matrix 3D, Richard Wittschiebe Hand and Heery International Inc. I appreciate your help?

***Answer: Designers of the project should not to be contacted directly; all questions must be given to DOP Contracting Officer Mr. Leslie Page.***

2. Question: Site Demolition plan, C4.1.1, Indicated the removal of existing overhead power line and power poles. Who is the owner of the overhead power line and the power poles. If the owner of the overhead power lines and poles is Georgia Power the scope of the contractor will be limited to utility coordination. Please clarify.

***Answer: The lights and poles in question are the property of the Airport and/or the present batch plant operator, the bid winner will coordinate with both parties to verify. Contractor will self-perform removal***

3. Question: Demolition plan for Gate 59 closure, C4.1.2, indicated the existing guard booth to be removed. But it does not mentioned where to take the removed guard booth. Please clarify.

***Answer: Guard booth to be removed and disposed of by contractor.***

4. Question: Is there Value available for FC-7489? Are all the Plans/Specs posted online?

***Answer: Detailed cost estimates for the Project are not publicly available at this time. Yes, the plans can be found on the City of Atlanta Aviation RFPs/Bids webpage in the Project listing's SOLICITATION – PDF section links. The specifications are found in the PROJECT NAME section FC7489 Relocation of Airport Escort Gate ITB link.***

**Addendum No. 3**

**Re: FC-7489; Relocation of Airport Escort Gate at Hartsfield-Jackson  
Atlanta International Airport**

August 14, 2014

Page 5

5. Question: Special Conditions SC-13 (Page 17 of 23) states "Contractor shall pay the prevailing wages as stipulated by the wage scale(s), which is incorporated in the Contract Documents (Section titled "WAGE AND BENEFIT RATES"). I am unable to find the referenced section in the Contract Documents. Please advise where the Wage Scale is located.

***Answer: SC-13 is removed from the Special Conditions.***

6. Question: Drainage Structure 00 is called out as a Headwall on 24" RCP. Can this structure be Precast Concrete or must it be Cast-in-Place Concrete?

***Answer: A 24" precast concrete headwall is acceptable.***

7. Question: Please advise what scope of work is included under Pay Item D-751-6.

***Answer: D-175-6 consists of concrete collars and other concrete for miscellaneous drainage purposes.***

8. Question: Can boots be used for pipes entering PCC structures in lieu of concrete collars?

***Answer: No. Concrete collars are required.***

**THE FOLLOWING ARE CHANGES AND/OR MODIFICATIONS TO THE BID DOCUMENTS**

**1. REVISION TO EXHIBIT "B" SPECIAL CONDITIONS**

Delete: "Exhibit "B" Special Conditions – SC-13 – Wage Requirements, in its entirety

***Replace With: "Exhibit "B" Special Conditions – SC-13 – Wage Requirements. This section is not applicable.***